



- NOTES:
1. TANKS ARE NOT PROVIDED BY FR MAHONY.
  2. ALL TANK PENETRATIONS BELOW AND INCLUDING THE RETURN/BACKWASH PIPE SHOULD INCORPORATE A WATER TIGHT BOOT SEALED WITH HYDRAULIC CEMENT.
  3. THE TOP ELEVATION OF THE AMPHIDROME REACTOR COVER WILL GOVERN FINAL GRADE.
- AND ALL OTHER MANHOLE RISERS SHOULD BE ADJUSTED ACCORDINGLY.

AMPHIDROME® SINGLE FAMILY LAYOUT			
Scale: NTS	Drawn By: ADW	Pion No.	Drawing 1
Date: 6/22/05	App'd By: PBP	Rev. No.	3
Water Supply & Pollution Control Equipment 273 Weymouth Street, Rockland, Massachusetts 02370			